

BOM TABLE			
ITEM	DESCRIPTION	PART NUMBER	QTY
1	BUSBAR	-	1
2	BRACKET	SCBKT-1	2
3	INSULATOR	4200S5 OR EQUIVALENT	2
4	3/8"X16 X 3/4" BOLT	-	4
5	3/8" LOCKWASHER	-	4

APPROVED
 1000-100
 08/20/08

INITIAL RELEASE			
JAS	JAS	8-18-2008	AO
BOM TABLE - PART #			
4200S5 WAS 215-3B			
JAS	JAS	11-14-2008	A1


NOTES:


1. UNLESS OTHERWISE SPECIFIED, ALL UNITS ARE IN INCHES. NON-LIMITED DIMENSIONS OTHER THAN SIZE OF RAW MATERIAL SHALL BE HELD AS FOLLOWS WHEN EXPRESSED:

- TO 2 DECIMAL PLACES ± .020
- TO 3 DECIMAL PLACES ± .010
- AS ANGLE ± 1 DEGREES
- AS DIAMETER 2 PLACES ± .015
- AS DIAMETER 3 PLACES ± .010

2. REMOVE ALL BURRS AND BREAK ALL SHARP EDGES.

3. FINISH:
 NONE



MATERIAL:		 STORM POWER COMPONENTS	
250 THICK COPPER C110 ALLOY PER ASTM B152/152M-06			
FINISH:	DESIGNED BY: JS	SCALE: NTS	REV
SEE NOTE 3	DATE: 8-20-2008	SCGBN-250412-0	A1